

Saia-Burgess Controls AG

Bahnhofstrasse 18, 3280 Murten, Switzerland
 T +41 26 580 30 00, F +41 26 580 34 99
 www.saia-pcd.com

Terminal block PCD2.K525

| | |
|-------------------------|-----|
| J1 | I/O |
| 2 | 15 |
| 4 | 14 |
| 6 | 13 |
| 8 | 12 |
| 10 | 11 |
| 12 | 10 |
| 14 | 9 |
| 16 | 8 |
| 18 | 7 |
| 20 | 6 |
| 22 | 5 |
| 24 | 4 |
| 26 | 3 |
| 28 | 2 |
| 30 | 1 |
| 32 | 0 |
| 1/3/5/7/17/ 19/21/23 | - |
| 9/11/13/15/ 25/27 | L/+ |

