
www.sbc-support.com





# PCD1.F2611-C15

# E-Line DALI module + auxillary RS-485





#### **Features**

- ► S-bus (RS-485) / DALI interface
- ► Incl. DALI voltage supply (can be deactivated)
- ▶ Up to 64 DALI ballasts
- ▶ 4 digital inputs
- ► Electrical isolation between supply, bus and I/Os
- ▶ Pluggable terminal blocks protected by flaps
- ► Status LEDs on the front
- ▶ RS-485, USB and NFC interface
- ► Freely programmable with Saia PG5®

### **General technical data**

#### **Power supply**

Supply voltage	Nominal 24 VAC (50 Hz) or DC 24 VDC, -15/+20% incl. 5% ripple 24 VAC, -15 %/+10 % (in accordance with EN/IEC 61131-2)
Electrically isolated	500 VDC between power supply and RS-485 as well as between power supply and inputs/outputs
Power consumption max.	2 W

#### **Interfaces**


Communications interface	RS-485 with galvanic isolation Baud rate: 9,600, 19,200, 38,400, 57,600, 115,200 bps (autobauding)
Address switch for S-Bus address	Two rotary switches 09 Address range 0253
Service interface	Micro USB NFC (Near Field Communication)
Additional interface	RS-485 in "Mode C" (without interpreted text). Baud rate: 1,200, 2,400, 4,800, 9,600, 19,200, 38,400, 57,600, 115,200 bps
Terminating resistor	Install externally


# General data

e Operation: 0 +55 °C Storage: −40 +70 °C
--

### **Dimensions and installation**







on DIN rails 35 mm (in accordance with DIN EN 60715 TH35)

Housing width 2 HP\* (35 mm) Compatible with electrical control cabinets (in accordance with DIN 43880, size  $2\times55$  mm)

\* Horizontal pitch: 1 HP corresponds to 17.5 mm

# Input/output configuration


#### Digital inputs

Number 4			
Input voltage	24 VAC / VDC source operation (positive switching) or sink operation		
Switching level Low: 05 V, High: 1524 V			
Input current	Typically 2 mA (AC/DC)		
Input delay	20 ms (AC), 2 / 8 / 50 ms (DC)		

# **DALI output**

Output voltage	1315.5V
Output current	Up to 160 mA

# **Connection example**



# **LEDs for the DALI line**

LED	Colour	Description
ID.	Green	Internal DALI supply active
IPw	Off	External supply active
Com	Flashing yellow	DALI communication is active
	Off	no DALI communication on the bus
Err	Red	If an error occurs on the DALI bus (e.g. a short-circuit)


# Internal / external DALI supply

The DALI bus can be supplied using the internal or via an external DALI supply in accordance with the IEC 62386-101 standard.



**Warning**: Observe the polarity when using an external supply. The module is not protected against incorrect polarity.

# **Assignment overview**







GND	Т	ground
DGND	TD	digital galvanic isolated ground
AGND	LΑ	analogue galvanic isolated ground
SGND	TS	signal ground
	a, b,	alphanumeric index by different grounds

# **Connection diagrams**

#### **Digital input**



### Additional RS-485 interface



#### **DALI** interface






The 27-606 PCD2 / PCD3.F26xx manual contains information regarding the DALI standard, cable recommendations, current, etc.

#### **Terminal technology**

Rigid or flexible wires with a diameter of up to 1.5 mm<sup>2</sup> can be used. A max. of 1 mm<sup>2</sup> is permitted with wire ferrules.


#### **Connection concept**

The device is supplied by a 24 VDC or AC voltage supply.



#### **Bus wiring**

DB- and /DA+ terminals must be used for exchanging data between the modules. The bus is through-wired to a terminal to ensure the exchange between modules to avoid an interruption in the bus connection.





Flexible RS-485 cables with a cross section of no more than 0.75 mm<sup>2</sup> are permissible for bus wiring. A cable cross section of 1.5 mm<sup>2</sup> per terminal applies overall. External bus terminating resistors must be used.

# **Programming**



The modules are programmed with Saia PG5° via a master controller or directly via Micro USB.

#### **Program**

Non-volatile memory (Flash memory)

Program blocks		
СОВ	COB 0	
XOB	XOB 10, 12, 13 and 16	
PB/FB	100 with maximum hierarchy of 8	
Data types		
ROM Text / DB	50	
Memory		
64 kByte	Program memory	

#### Media

Volatile memory (RAM) without battery backup

Data types		
2000	Register	
2000	Flag	
200	Timer / Counter	
Memory		
5 kByte	Memory (RAM) for 50 Text/DB	
2 kByte	Memory (EEPROM) for up to 500 parameters (media) backup	
Real-time clock (RTC)	Cyclic synchronisation with PCD controller	

# **Supported libraries**

The modules are planned with Saia PG5® using FBoxes or IL. The Saia PG5® Fupla Editor provides a selection of FBoxes which significantly simplify engineering.

PG5 standard FBox libraries:

▶ Binary▶ Flip-Flop▶ Blinker▶ Floating Point

▶ Blinker
 ▶ Floating Point (IEEE only)
 ▶ Block Control (without SB)
 ▶ HVC (partly)

▶ Buffers ▶ Indirect

Com.Text (not interpreted)
 Converter
 Counter
 Move In/Out

▶ DALI E-Line Driver (new)▶ MP-Bus▶ Data Block▶ Regulation

▶ Data Buffer ▶ Special, sys info (partly)

▶ EIB Driver (partly) ▶ Timer

► EnOcean (partly)

In addition to these libraries, an "E-Suite" library is available for specific applications that can be created with the Saia PCD1 E-Line modules. An example for the electrical plant: shade control, light dimming,...








#### **DALI library**

The DALI master module includes the Bus power supply for up to 64 DALI participants. The extensive PG5 FBox library has function modules for commissioning, operating and servicing with the PLC program. The "DALI E-Line driver" library is included in the "DALI F26xx driver" library.

Smaller DALI controls can be implemented with the PCD1.F2611-C15 E-Line DALI module.







Further information, including which FBoxes are supported, Getting Started, etc. can be found on our support page <a href="https://www.sbc-support.com">www.sbc-support.com</a>

(partly)



## **ATTENTION**

These devices must only be installed by a professional electrician, otherwise there is the risk of fire or the risk of an electric shock.



#### **WARNING**

Product is not intended to be used in safety critical applications, using it in safety critical applications is unsafe.



# **WARNING - Safety**

The unit is not suitable for the explosion-proof areas and the areas of use excluded in EN 61010 Part 1.



# **WARNING - Safety**

Check compliance with nominal voltage before commissioning the device (see type label). Check that connection cables are free from damage and that, when wiring up the device, they are not connected to voltage.



#### NOTE

In order to avoid moisture in the device due to condensate build-up, acclimatise the device at room temperature for about half an hour before connecting.



# **CLEANING**

The device can be cleaned in dead state with a dry cloth or cloth soaked in soap solution. Do not use caustic or solvent-containing substances for cleaning.



## **MAINTENANCE**

These devices are maintenance-free. If damaged during transportation or storage, no repairs should be undertaken by the user.



#### **GUARANTEE**

Opening the module invalidates the guarantee.



## WEEE Directive 2012/19/EC Waste Electrical and Electronic Equipment directive

The product should not be disposed of with other household waste. Check for the nearest authorized collection centers or authorized recyclers. The correct disposal of end-of-life equipment will help prevent potential negative consequences for the environment and human health.



EAC Mark of Conformity for Machinery Exports to Russia, Kazakhstan or Belarus.





PCD1.F2611-C15

# **Order details**

Туре	Short description	Description	Weight
PCD1.F2611-C15	Saia PCD® E-Line programmable modules	Programmable E-Line DALI module for up to 64 DALI ballasts with integrated DALI-Bus power supply supply 24 VAC/VDC 4 digital inputs 24 VAC/VDC 4 interfaces: RS-485 (S-Bus), auxiliary RS-485, USB & NFC (service)	129 g
32304321-003-S	Terminal set	6-pin terminal. Set of 6 terminal blocks	40 g

Bahnhofstrasse 18 | 3280 Murten, Switzerland T +41 26 580 30 00 | F +41 26 580 34 99 www.saia-pcd.com