


## Saia PCD7.D457VTCZ42 (VGA MB-Panel) Release Note

### HW/FW Version of this PCD7.D457VTCZ42

HW version delivered	HW Version B1 or higher
Dedicated Firmware equipped from factory	V1.18.13949_ela

This system is developed according to the international standard EN/IEC61131-2:2007 for controller and complies with CE conformity and most Shipping Approval Norms (like DetNorske Veritas and others). Details on request).

### Additional technical specification:

UL Compliance	Conformité UL selon les conditions suivantes
 <p><b>According to the following conditions</b></p>	
For use on a Flat Surface of a Type 1 Enclosure.	Pour une utilisation sur une surface plane de « Enclosure Type 1 ».
Use 60/75°C copper (CU) wire only.	N'utiliser que des fils de cuivre, isolation 60/75°C.
Caution: do not connect directly to line voltage. Line voltage must be supplied by a suitable, approved 24 VDC isolating transformer having short circuit capacity not exceeding 100 VA maximum and with secondary protected by a 4A UL248 listed fuse“.	Attention: ne pas connecter directement à la tension de ligne. La tension de ligne conforme 24VDC doit provenir d'un transformateur isolé approuvé ayant une capacité de court-circuit ne dépassant pas 100 VA maximum et dont le secondaire est protégée par un fusible 4 A UL248 classé.
This device is suitable for use in a 55 degrees C max ambient.	Ce dispositif est adapté pour une utilisation dans une ambiance de 55 degrés C max.

### Firmware

- The FW can be updated via the USB or TCP/IP port. Please refer to the manual for the FW-Update procedure or check site below for new versions.
- By restoring the default parameter (via Setup Menu), your data will be restored based on ELA Default Settings. More information on request.

### Further information and support

In order to maintain the lifetime of the Backlight LCD it is recommended to work at temperature between 10°C and 35°C. Please refer to the Manual for more information.

Further information and Software/COSinus-Updates are available on [www.sbc-support.com](http://www.sbc-support.com)

### Disclaimer

The plant engineer contributes his share to the reliable operation of an installation. He is responsible for ensuring that controller use conforms to the technical data and that no excessive stresses are placed on it, e.g. with regard to temperature ranges, over voltages and noise fields or mechanical stresses. In addition, the plant engineer is also responsible for ensuring that a faulty product in no case leads to personal injury or even death, nor to the damage or destruction of property. The relevant safety regulations must always be observed. Dangerous faults must be recognized by additional measures and any consequences prevented. Consistent use of the diagnostic elements of the PCD, such as the watchdog, exception organization blocks (XOB) and test or diagnostic instructions shall be made.