


# PCD3.W600

Analog output module,  
4 channel, 12 Bit, 0 ... 10 V



High-speed output module for general use with 4 channels, each with 12 bit resolution and voltage 0 ... 10 V.




PCD3.W600

### Technical specifications


Number of outputs (channels)	4, short circuit protected
Signal range	0 ... 10 V
Resolution (representation)	12 bit (0 ... 4095)
Resolution (value of least significant bit[LSB])	2.442 mV
Galvanic separation	no
Conversion time A/D	typically 10 µs
Load impedance	Voltage: > 3 kΩ
Repeating accuracy (under same conditions)	Voltage: ± 0.5 %
Temperature error (over temperature range 0 ... +55 °C)	Voltage: ± 0.1 %
Internal current consumption (from +5 V bus)	max. 4 mA
Internal current consumption (from V+ bus)	max. 20 mA
External current consumption	0 mA
Terminals	Pluggable 10-pole spring terminal block for Ø up to 2.5 mm <sup>2</sup> , plug type A (4 405 4954 0)

### Block schematic



Typ: PCD3.W600, PCD3.W610

### Indicators and connections






I/O modules and I/O terminal blocks may only **be plugged** in and removed when the CPU and the external +24 V are disconnected from the power supply.

## Principle diagram of analog outputs

### Output connection for 0 ... 10 V



During start-up, a voltage of 5 V is sent to all outputs of the W600 module. The start-up phase lasts 40 ms, then 0 V is sent to the outputs.




The external power supply of 24 VDC at terminals 8 and 9 is not required.

## Connection concept


The voltage input signals are connected directly to the 10-pole terminal block. To minimize the amount of interference coupled into the module via the transmission lines, connection should be made according to the principle explained below.

### Connection for 0 ... 10 V



## Configuration

### HPS Control Edge Builder

HPCD-System	Evaluation
HPCD3.M6893	<p>The evaluation is performed by the firmware. It reads the values according to the configuration (Device Configurator)</p> 



PCD3.W600



4 405 4954 0

### Ordering information

Type	Short description	Description	Weight
PCD3.W600	4 analogue outputs, 12 bit. 0 ... 10 V	Analogue output modules, 4 inputs (channels), resolution 12 bit, signal range 0 ... 10 V. The channels themselves not separated. Connection with pluggable spring terminals, plug-in type A (4 405 4954 0) included	80 g

### Ordering information equipment

Type	Short description	Description	Weight
4 405 4954 0	Plug-in, type A	Plug-in I/O spring terminal block, 10-pole up to 2.5 mm <sup>2</sup> , labelled 0 ... 9	15 g

**ATTENTION**

These devices must only be installed by a professional electrician, otherwise there is the risk of fire or the risk of an electric shock.

**WARNING**

Product is not intended to be used in safety critical applications, using it in safety critical applications is unsafe.

**WARNING - SAFETY**

The unit is not suitable for the explosion-proof areas and the areas of use excluded in EN61010 Part 1.

**WARNING - SAFETY**

Check compliance with nominal voltage before commissioning the device (see type label). Check that connection cables are free from damage and that, when wiring up the device, they are not connected to voltage. Do not use a damaged device !

**NOTE**

In order to avoid moisture in the device due to condensate build-up, acclimatise the device at room temperature for about half an hour before connecting.

**CLEANING**

The device can be cleaned in dead state with a dry cloth or cloth soaked in soap solution. Do not use caustic or solvent-containing substances for cleaning.

**MAINTENANCE**

These devices are maintenance-free.  
If damaged during, no repairs should be undertaken by the user.



Observe this instructions (data sheet) and keep them in a safe place.  
Pass on the instructions (data sheet) to any future user.

**WEEE Directive 2012/19/EC Waste Electrical and Electronic Equipment directive**

The product should not be disposed of with other household waste. Check for the nearest authorized collection centers or authorized recyclers. The correct disposal of end-of-life equipment will help prevent potential negative consequences for the environment and human health.



EAC Mark of Conformity for Machinery Exports to Russia, Kazakhstan or Belarus.

## Sales and Service

For application assistance, current specifications, pricing, or name of the nearest Authorized Distributor, contact one of the offices below.

### ASIA PACIFIC

Honeywell Process Solutions,  
(TAC) [hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

#### Australia

Honeywell Limited  
Phone: +(61) 7-3846 1255  
FAX: +(61) 7-3840 6481  
Toll Free 1300-36-39-36  
Toll Free Fax:  
1300-36-04-70

#### China – PRC - Shanghai

Honeywell China Inc.  
Phone: (86-21) 5257-4568  
Fax: (86-21) 6237-2826

#### Singapore

Honeywell Pte Ltd.  
Phone: +(65) 6580 3278  
Fax: +(65) 6445-3033

#### South Korea

Honeywell Korea Co Ltd  
Phone: +(822) 799 6114  
Fax: +(822) 792 9015

### EMEA

Honeywell Process Solutions,  
Phone: +80012026455 or  
+44 (0)1344 656000

Email: (Sales)  
[FP-Sales-Apps@Honeywell.com](mailto:FP-Sales-Apps@Honeywell.com)  
or  
(TAC) [hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

### AMERICA'S

Honeywell Process Solutions,  
Phone: (TAC) 1-800-423-9883 or  
215/641-3610  
(Sales) 1-800-343-0228

Email: (Sales)  
[FP-Sales-Apps@Honeywell.com](mailto:FP-Sales-Apps@Honeywell.com)  
or  
(TAC) [hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

### WARRANTY / REMEDY

Honeywell warrants goods of its manufacture as being free of defective materials and faulty workmanship. Contact your local sales office for warranty information. If warranted goods are returned to Honeywell during the period of coverage, Honeywell will repair or replace without charge those items it finds defective. The foregoing is Buyer's sole remedy and is **in lieu of all other warranties, expressed or implied, including those of merchantability and fitness for a particular purpose.** Specifications may change without notice. The information we supply is believed to be accurate and reliable as of this printing. However, we assume no responsibility for its use. While we provide application assistance personally, through our literature and the Honeywell web site, it is up to the customer to determine the suitability of the product in the application.

***Specifications are subject to change without notice.***

---

### For more information

Learn more about ControlEdge PCD, visit our website  
[www.honeywellprocess.com/ControlEdgePCD](http://www.honeywellprocess.com/ControlEdgePCD) or  
contact your Honeywell account manager.

### Honeywell Process Solutions

2101 CityWest Blvd, Houston TX 77042  
Honeywell House, Skimped Hill Lane

Bracknell, Berkshire, England RG12 1EB UK  
Building #1, 555 Huanke Road,

Zhangjiang Hi-Tech Industrial Park,  
Pudong New Area, Shanghai 201203

©2020 Honeywell International Inc.

Document No.: 51-52-03-92  
Rev. Rev.2.1

November 2020

**Honeywell**