

AMEV attestation for certified BACnet devices

1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	Saia-Burgess Controls AG		
Product name	Saia PCD3 Extended Line		
Product model number	PCD3.M5340, PCD3.M5540, PCD3.M5560, PCD3.M6360, PCD3.M6560, PCD3.M6860		
Standard device profile	B-BC	BACnet protocol vers. / rev.	1.9
Firmware revision	1.22.29		

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 19200, 38400, 115200	
	<input type="checkbox"/>	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input checked="" type="checkbox"/> Router, medium: BACnet/IP, MS/TP	
Character sets	<input type="checkbox"/> UTF-8	<input checked="" type="checkbox"/> ANSI X3.4
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of:
<input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: V 1.1 21.08.2012
<input type="checkbox"/> AMEV profile	As of:

3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab MBS dated 29.01.2014 number VG 2012_7293
<input checked="" type="checkbox"/> AMEV recommendation BACnet V 1.1 As of: 21.08.2012 (see www.amev-online.de)

4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BAC-0146 (see http://www.big-eu.org/en/products/certified-products)
--

Stuttgart, 20.08.2014



Dr.-Ing. Bernhard Hall,
Vermögen und Bau Baden-Württemberg
Rotebühlplatz 30
70195 Stuttgart
Telefon +49 711 6673-3423
Email Bernhard.Hall@Vbv.bwl.de

(AMEV chairman BACnet)



WSPCert

Dr.-Ing. Frank Bitter
Kapuzinerweg 7
D-70374 Stuttgart
Telefon +49 711 953922-0
Telefax +49 711 953922-66

(BACnet certification body)