

Template Category	Controller			
Template Version	a			
Category Description	Saia PCD® modular programmable controllers			
Classification System				
Classification	PCD3 processor unit with Ethernet TCP/IP			
Suitability for Use	Provisional			
Template Custodian	BCIA			
Information Category	Parameter Name	Value	Units	Notes
Manufactu				
Specifications Specifications	Manufacturer Manufacturer Website	Saia-Burgess Controls AG http://www.saia-pcd.com	Text URL	
Specifications	Product Range	CPU base units for 4 plug-in I/O modules - Saia PCD3.M5 series	Text	
Specifications	Product Model Number	PCD3.M5560	Text	Or Code
Specifications	CE Approval Product Literature	Yes http://www.sbc-support.com	Text URL	Number, Yes, No
Specifications Specifications	Product Literature	PCD3 processor unit with Ethernet TCP/IP, web and FTP server, file	UKL	
	Features	system, CPU with 2 MByte user program, 1 MByte SRam extension memory, 128 MByte user Flash memory with file system, USB port for PG5, up to 1024 I/O, 2 interrupts, RS-232, 2x RS-485 for Profi-S-Net/MPI/S-Bus, data protection 1-3 years	Text	Free text to describe product
Construction		IDlastic appared alestropic device	Tave	This is a CODistical asker fields will be required in final DDTs
Specifications Specifications	Type Mounting	Plastic encased electronic device 35 mm DIN hat rail	Text Text	This is a COBie field, other fields will be required in final PDTs This is a COBie field, other fields will be required in final PDTs
Specifications	Shape	Rectangle	Text	This is a COBie field, other fields will be required in final PDTs
Specifications	Material	Plastic	Text	This is a COBie field, other fields will be required in final PDTs
Specifications Specifications	Colour Finish	Light Grey Matt	Text Text	This is a COBie field, other fields will be required in final PDTs This is a COBie field, other fields will be required in final PDTs
Specifications	Enclosure Rating	Watt		IP rating
Application				
	Reference Standard Certifications	requested CE	Text Text	
Dimension			TOXU	
Specifications	Overall Depth	139.00		Or Diameter. Minimum and maximum lengths available
•	Overall Width Overall Height	180.00 100.50		Minimum and maximum widths available
Specifications Specifications	Gross Weight	0.82		Minimum and maximum heights available Equates to Operating Weight
Specifications	Shipping Weight		kg	Equates to dry weight of unit plus packaging allowance
Specifications	Access Clearance Top	20.00		Access required for maintenance of this item
Specifications Specifications	Access Clearance Bottom Access Clearance Left	20.00		Access required for maintenance of this item Access required for maintenance of this item
Specifications	Access Clearance Right	0.00		Access required for maintenance of this item Access required for maintenance of this item
Specifications	Access Clearance Front	20.00		Access required for maintenance of this item
Specifications Performan	Access Clearance Rear	0.00	mm	Access required for maintenance of this item
Specifications	Ambient Storage Limits Temperature	−40+70 °C	Degrees C	
Specifications	Ambient Operation Limits Temperature	+0+55 °C	Degrees C	
Specifications	Ambient Operating Limits Humidity		Percentage	
	Altitude Data (if required)		sea level	
	Supply voltage	24 VDC -20%/+25%	Volts	
Specifications	Current consumption		Α	
Specifications Controls	Power consumption	typ. 15 W	W	
	On-Board I/Os	0	Number	
Specifications	Max. I/Os		Number	
Specifications	Max. Interfaces	13	Number	
Sustainabi Sustainable Material BREEAM etc	Embodied Carbon		kaCO2	AWAITING INDUSTRY STANDARD
Sustainable Material BREEAM etc	Life Cycle Analysis		kgCO2 Number	AWAITING INDUSTRY STANDARD AWAITING INDUSTRY STANDARD
Sustainable Material BREEAM etc	Location of Manufacturer	46° 55' 31.28" North, 7° 6' 51.53" East	GridRef	AWAITING INDUSTRY STANDARD
	Green Guide for Specification		Text	AWAITING INDUSTRY STANDARD
Sustainable Material BREEAM etc Sustainable Material BREEAM etc	Environmental Product Declaration Responsible Sourcing of Materials		Text Text	3rd Party Verification or Self Verification with URL to document AWAITING INDUSTRY STANDARD
Sustainable Material ETL	Energy Technology List		URL	Hyperlink to ETL webpage for product or N/A
Sustainable Material LEED v.4	Responsible Extraction of Materials		Text	AWAITING INDUSTRY STANDARD
	Material Ingredient Reporting		Text	AWAITING INDUSTRY STANDARD
	RoHS compliant WEE compliant		Y/N Y/N	
Operations	s & Maintenance			
acilities/Asset Management	O&M Manual	https://www.sbc-support.com	URL	Hyperlink to Manufacturer O&M Data
Facilities/Asset Management Facilities/Asset Management	Daily Weekly	n/a n/a	Text Text	Maintenance tasks or SFG2012 codes Maintenance tasks or SFG2012 codes
Facilities/Asset Management	Monthly	n/a		Maintenance tasks of SFG2012 codes
	Quarterly	n/a		Maintenance tasks or SFG2012 codes
acilities/Asset Management	6 Monthly	n/a n/a	Text Text	Maintenance tasks or SFG2012 codes Maintenance tasks or SFG2012 codes
Facilities/Asset Management Facilities/Asset Management		1.0 %	Text	Maintenance tasks of SFG2012 codes Maintenance tasks or SFG2012 codes
Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management	Annually Bespoke Timeframe	n/a		
Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs	n/a	Text	Maintenance tasks required during this time frame
Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs Maintenance Required 301-600hrs	n/a n/a	Text	Maintenance tasks required during this time frame
Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs Maintenance Required 301-600hrs Maintenance Required 601-1000hrs	n/a n/a n/a	Text Text	Maintenance tasks required during this time frame Maintenance tasks required during this time frame
Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs Maintenance Required 301-600hrs	n/a n/a	Text Text Text Text	Maintenance tasks required during this time frame
Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs Maintenance Required 301-600hrs Maintenance Required 601-1000hrs Maintenance Required 1001-2000hrs Maintenance Required 2001-4000hrs Maintenance Required 40001-8000hrs	n/a	Text Text Text Text Text Text	Maintenance tasks required during this time frame
Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs Maintenance Required 301-600hrs Maintenance Required 601-1000hrs Maintenance Required 1001-2000hrs Maintenance Required 2001-4000hrs Maintenance Required 40001-8000hrs Maintenance Required 8001-12000hrs	n/a n/a n/a n/a n/a n/a n/a n/a	Text Text Text Text Text Text Text Text	Maintenance tasks required during this time frame
Facilities/Asset Management	Annually Bespoke Timeframe Maintenance Required 0-300hrs Maintenance Required 301-600hrs Maintenance Required 601-1000hrs Maintenance Required 1001-2000hrs Maintenance Required 2001-4000hrs Maintenance Required 40001-8000hrs	n/a	Text Text Text Text Text Text	Maintenance tasks required during this time frame